



**State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES**

6 Hazen Drive, P.O. Box 95, Concord, NH 03302-0095
(603) 271-3501 FAX (603) 271-6683



LETTER OF DEFICIENCY

No. WD SS 02-02

January 8, 2002

Mr. Robert E. Cutter
224 Black Hall Road
Epsom, NH 03234

RE: Therrien, Old Town Road Ext., Epsom

Dear Mr. Cutter

On January 7, 2002, personnel from the Department of Environmental Services, Water Division ("DES") received a complaint concerning the Therrien property, described as Lot #10-29, on Tax Map # U-10, and located on Old Town Road Extended, Epsom, NH, ("the Property"). The purpose of this complaint was to question whether you were in compliance with RSA 485-A and its implementing regulations, the Subdivision and Individual Sewage Disposal System Design Rules, Env-Ws 1000 ("the Rules").

As a result of the complaint, the following deficiency was noted

1. The vent pipe in the septic system on the Property has been cut off and sealed, in violation of CA2000027680-A.

DES expects the above deficiency to be permanently corrected within 10 days by initiating and completing the following measures:

Re-install a full, open vent pipe into the system on the Property to replace the vent pipe you removed earlier.

DES believes the cited deficiencies will be corrected within 10 days and a report describing the corrective measures can be submitted to this office within 14 days of receipt of this letter.

In the event compliance is not achieved within this period, DES may take further action against you, including issuing an order requiring the above items to be corrected, initiating an administrative fine proceeding, and/or referring the matter to the New Hampshire Department of Justice for imposition of civil and/or criminal penalties. In

addition, DES personnel will inspect the Property at a later date to determine whether you have come into, and are maintaining, full compliance with all applicable statutes and directives.

The written report as requested above should be addressed as follows

Richard J. de Seve, SSB, DES
Department of Environmental Services
6 Hazen Drive, PO Box 95
Concord, NH 03302-0095

Your prompt cooperation is appreciated. Should you have any questions regarding this letter, please contact Richard J. de Seve at 271-3442.

Sincerely,

 **COPY**

William E. Evans, P.E.
Administrator
Subsurface Systems Bureau

WEE/RJD

CERTIFIED MAIL 7099 3400 0003 0695 8951

Cc: James G. Falicon, SSB, DES
Gretchen C. Rule, Enforcement Coordinator, DES ✓
Russell A. Nylander, Chief Engineer, WD
Board of Selectmen, Town of Epsom
Richard J. de Seve, SSB, DES
M. Therrien